



**GENERAL NOTES:**

1. CULINARY WATER LATERALS MUST BE LAID AT LEAST TEN FEET (EDGE-TO-EDGE) FROM ANY EXISTING OR PROPOSED SEWER LATERAL.
2. WHERE WATER AND SEWER LATERALS MUST CROSS, WATER LATERAL SHALL BE 18" ABOVE THE SEWER LATERAL AS MEASURED FROM THE BOTTOM OF THE WATER LATERAL TO THE TOP OF THE SEWER LATERAL. THIS SEPARATION SHALL BE MAINTAINED FOR A MINIMUM OF 10'-0" EITHER SIDE OF THE CROSSING POINT.
3. TEFLON TAPE REQUIRED ON ALL THREADED CONNECTIONS.
4. ALL SERVICE LATERALS SHALL BE BEDDED & BACKFILLED WITH SAND OR AN APPROVED EQUAL. PEA GRAVEL SHALL NOT BE ACCEPTED.
5. CULINARY WATER SERVICE METERS MAY BE PLACED IN PLANTER STRIPS, IF PRESENT.
6. CONTRACTOR SHALL SPLICE AND RE-CONNECT ALL TRACING WIRE WITH GREASED WIRE NUTS.
7. ALL METER BOX LIDS WITHIN CONCRETE SHALL BE D&L SUPPLY MODEL B-5021.

CORPORATION STOP  
FLARED CONNECTION  
MUELLER OR APPROVED  
EQUAL

CULINARY WATER MAIN

TAPPING SADDLE  
BRASS DOUBLE STRAP FOR PVC.  
BRASS SINGLE STRAP FOR  
DUCTILE IRON.

SEE NOTE 6

**CULINARY WATER SERVICE  
CONNECTION DETAIL**



**CEDAR HILLS**  
STANDARD  
DRAWING NO.  
**406**