

## PRESSURIZED IRRIGATION CONNECTION GUIDE

- A. Existing stop and waste valve. (This valve is for city use only. Must be made accessible to the city by water user.)
- B. Irrigation box containing water user installed shutoff valve (for use by the water user) and appropriate filter.
- C. Minimum three feet of straight pipe (for future water meter if city deems necessary).
- D. Connection to new or existing sprinkler system.
- E. Disconnection of sprinkling system from culinary water supply. Minimum one foot of pipe must be removed and capped off. Disconnection must be inspected by the city at the same time new irrigation connection is inspected. **No swing or any other kind of cross connection is allowed.**
- F. Stop and waste valve connecting culinary water system to sprinkling system. Removal of this valve is recommended but not mandatory.
- G. Culinary water meter and service line to home.

Note: Placement of sprinkler pipes and service connections will vary. If there are any questions about appropriate parts, placement and/or connections please contact the City.

