



GENERAL NOTES:

1. LATERALS SHALL NOT ENTER MANHOLES UNLESS OTHERWISE APPROVED BY CITY ENGINEER.
2. SEWER LATERALS HAVE THE SAME BEDDING REQUIREMENTS, BOTH IN MATERIAL AND DIMENSIONS OF BEDDING, AS THE SEWER MAIN LINE.
3. SEWER LATERALS MUST BE LAID AT LEAST TEN FEET (EDGE TO EDGE) HORIZONTALLY FROM ANY EXISTING OR PROPOSED CULINARY WATER LATERAL.
4. ALL SEWER LATERALS SHALL BE BEDDED & BACKFILLED WITH SAND OR AN APPROVED EQUAL. PEA GRAVEL SHALL NOT BE ACCEPTED.
5. CLEANOUTS SHALL BE REQUIRED EVERY 50' OR AT EVERY BEND.



CEDAR HILLS

STANDARD
DRAWING NO.

302

SEWER LATERAL DETAIL