

TYPE I

TYPE II


GENERAL NOTES:

1. PLACE BACKFILL IN PIPE ZONE AT OPTIMUM MOISTURE IN HORIZONTAL 12" DEEP LOOSE LAYERS. COMPACT TO A 95% STANDARD PROCTOR DRY DENSITY (ASTM D-698).
2. "O.D." MEANS OUTSIDE DIAMETER OF PIPE BARREL.  
"I.D." MEANS INSIDE DIAMETER OF PIPE BARREL.
3. MAXIMUM WIDTH OF TRENCH MEASURED AT THE TOP OF THE PIPE, INCLUDING ANY NECESSARY SHEATHING IS AS FOLLOWS:

<u>PIPE I.D.</u>	<u>MAX. TRENCH WIDTH</u>
LESS THAN 33"	O.D. + 24"
GREATER THAN 33"	O.D. + 30"

CHANGES IN MAXIMUM WIDTHS ONLY AS APPROVED BY THE CITY ENGINEER.

4. FOR FOUNDATION STABILIZATION USE STABILIZATION MATERIAL CONFORMING TO CITY OF CEDAR HILLS SPECIFICATIONS. DEPTH AS REQUIRED AND APPROVED BY THE CITY ENGINEER.
5. BEDDING MATERIAL AND MODIFIED BEDDING MATERIALS SHALL CONFORM TO CITY OF CEDAR HILLS SPECIFICATIONS COVERING THESE MATERIALS.
6. PEA GRAVEL SHALL NOT BE ACCEPTED AS A BEDDING OR BACKFILL MATERIAL.



**CEDAR HILLS**

STANDARD  
DRAWING NO.

501

PIPE BEDDING